SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 25-09-2026

No. PHC/ESTA/WC/ 134 /2026

It is certified that an inspection team headed by DR VISHAL D DEGARMA, MEDICAL OFFICER

(Name of Officers with designation) from PHC KHOKHADDAD PHED

inspected the SRI SRI ACADEMY,SITUATED OPP.VINAYAK FARM ,CHRIST COLLEGE ROAD,VEJAGAM. (Name & Address of the school) on 25-09-2026(date of inspection) and on the basis of Water Test Report (Attached) bearing no.E/2609396

dated.19-09-2026 of ENVITRO LAB (PHED Lab) certified that the SRI SRI ACADEMY(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till FOR TWO YEARS

Signature with Seal: મેડીકલ ઓફીસર, પ્રાથમિક આરોગ્ય કેન્દ્ર ખોખડદડ.

Name : ડો. વિશાલ દેગરમા

Designation : મેડિકલ ઓફિસર

Name & Address of the Office / Department : PHC ખોખડદડ.

To

SRI SRI ACADEMY

VEJAGAM.

(Name & Address of the Institution)

ENVITRO GROUP OF COMPANIES

Envitro LABORATORIES ESTD. 2007 — THE LEADING EDGE IN SCIENCE

TEST REPORT

TEST REPORT No. : E/2609396
DATE OF ISSUE: 19/09/2026
REPORT ISSUED To : Sri Sri Academy-Vejagam
ADDRESS : Rajkot
SAMPLE COLLECTED BY : Self
SAMPLE DESCRIPTION : R.O Water

QUANTITY	BATCH NO.	DOM	DOE
1 Liter	Not Mention	Not Mention	Not Mention
DATE OF RECEIPT	DATE OF START ANALYSIS : 18/09/2026		
18/09/2026	DATE OF COMPLETION OF ANALYSIS : 19/09/2026		

CHEMICAL PARAMETERS:

SR. NO.	TEST PARAMETER	UNIT	METHOD	REQUIREMENT IS - 10500:2012 (2nd Revision)	RESULT
1.	pH	---	IS 3025 (Part 11)	6.5 - 8.5	7.84
2.	Total Dissolved Solids (TDS)	mg/l	IS 3025 (Part 16)	Max. 500	104
3.	Total Hardness	mg/l	IS 3025 (Part 21)	Max. 200	65.28
4.	Turbidity	NTU	IS 3025 (Part 10)	Max. 1	0.1
5.	Colour	Hazen Units	IS 3025 (Part 4)	Max. 5	1
6.	Electric conductivity	mS/cm	IS 3025 (Part 14)	---	0.172
7.	Calcium	mg/l	IS 3025 (Part 40)	Max. 75	14.81
8.	Chloride	mg/l	IS 3025 (Part 32)	Max. 250	26.54
9.	Magnesium	mg/l	IS 3025 (Part 46)	Max. 30	5.94
10.	Total Alkalinity	mg/l	IS 3025 (Part 23)	Max. 200	54.6
11.	Nitrate	mg/l	IS 3025 (Part 34)	Max. 45	B.D.L(DL=1.0)
12.	Sulphate	mg/l	IS 3025 (Part 24)	Max. 200	7.032
13.	Fluoride	mg/l	IS 3025 (Part 60)	Max. 1	B.D.L(DL=0.25)

MICROBIOLOGICAL PARAMETERS:

SR. NO.	PARAMETER	UNIT	METHOD	REQUIREMENT	RESULT
1.	E. coli	Detection/ 100 ml	IS 1622	Shall not be detectable in any 100 ml sample	Absent
2.	Total Coliform	Detection/ 100 ml	IS 1622	Shall not be detectable in any 100 ml sample	Absent

* BDL = Below Detection Limit, DL = Detection Limit

Opinion: The water sample is complies with the specified requirements of IS 10500:2012 for the parameters tested.

REMARKS:

1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from **The Director, ENVITRO LABORATORIES, RAJKOT.**
2 The test report pertains to the sample tested.
3 Sample not drawn by us.
4 The Information about sample, and customer details provided by customer & Testing carried out according to customers request only.

Tested By
LAB ANALYST

Envitro Laboratories Pvt. Ltd. Envitro LABORATORIES Rajkot

Issues By
TM/QM

*** End of Report ***

9001:2015 | 14001:2015 | 45001:2018 | Govt of India Approved | ICAR Granted | MOFPI Granted | GPCB Sc-|| Auditor | GERI Gujarat Registered

ENVITRO LABORATORIES PVT.LTD.
"Envitro Group of Companies", 6-Navalnagar Corner, Mavdi Main Road, Rajkot-360004.
+91 281 2366430|+91 99042 27274 |+91 9227133993 envitrolabs@gmail.com www.envitrolabs.com